

Government Of West Bengal Office Of The Divisional Fire Officer, Purba Medinipur West Bengal Fire & Emergency Services Dharinda, P.O.:- Tamluk, Purba Medinipur, Pin:- 721636

Memo no.:WBFES/HOW/413/15

Date: 15-09-2022

From:

Divisional Fire Officer, Purba Medinipur West Bengal Fire & Emergency Services

To: ZILLA PUBLIC SCHOOL TAMLUK, PURBA MEDINIPUR

Sub: Fire Safety Certificate for an existing G+II storled building under group of Educational Occupancy in the name & style of "ZILLA PUBLIC SCHOOL" at the premises of PLOT NO- 420,423,424,425, KHATIAN NO- 7860, HOLDING NO- 271/A, J.L. NO- 277, MOUZA- Sankarara, WARD NO.- NEW- 15, P.O.- Tamluk, P.S.- Tamluk, District-Purba Medinipur, PIN- 721636.

This is in reference to your application no. 0125189221400079 dated 09-09-2022 regarding the Fire Safety Certificate for an existing G+II storied building under group of Educational Occupancy in the name & style of "ZILLA PUBLIC SCHOOL" at the premises of PLOT NO- 420,423,424,425, KHATIAN NO- 7860, HOLDING NO- 271/A, J.L. NO- 277, MOUZA-Sankarara, WARD NO.- NEW- 15, P.O.- Tamluk, P.S.- Tamluk, District- Purba Medinipur, PIN- 721636.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

However, to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

- 1.All the Fire Safety Recommendation which was issued by this office vides memo no.- WBFES/HOW/413/15 Dt-27.01.2021 to be followed strictly at all time.
- 2.Driveway must be free from any type of obstruction for easy movement of fire appliances. No parking will be allowed on the driveway.
- 3. The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
- 4.To eliminate risk of fire hazards, Good House keeping both for inside and outside of the building shall be strictly
- 5. Electrical wiring of the whole building shall have to be carefully checked for any wire and tear in them, particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March in every year.
- 6.A fire control room including a CCTV system will have to be maintained, which observe all floor of the building.
- 7. The notice of fire fighting and Evacuation from the shall be prepared and displayed at all venerable of the pullding.

The authenticity of this document can be verified by accessing the URL: edistrict, who giv in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number: 0125189221400079.

Manager Zilla Public School प्राचार्य / Principal जिला पब्लिक स्कूल, तमलुक Zilla Public School, Tamluk

- 8. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of fire and testing.
- 9. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 10. Electrical installation room shall be protected with automatic CO2 or D.C.P. Fire extinguishers confirming 1.5. Specification.
- 11.Unauthorized cooking arrangement in any floor of the Nursing Home by using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
- 12.Arrangement shall have to be made for regular checking, testing and maintenance of all fire fighting installation in the building to keep them in perfectly good working condition at all the items.
- 13.Periodical flashing of water in the Hose reel hose pipe line shall made to maintain the efficiency working performance of above mention system.
- 14. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
- 15. This certificate valid for 03 year from the date of issuance of this certificate.

A renewal certificate is to be obtained in every three year from the Director General, West Bengal Fire & Emergency Services for performance of all the life & fire safety arrangements and installations of the building.

Signature Not Verified

Dyshilly Egyad.

Although Kinner Approved

Data 15-dep-2027 18-80-41

Reston Approved

Location West Bergan

Divisional Fire Officer, Purba Medinipur West Bengal Fire & Emergency Services

प्राचार्य / Principal जिला पब्लिक स्कूल, तमलुक Zilla Public School, Tamluk Manager Zilla Public School

The authenticity of this document can be verified by accessing the URL: ediatric who provided then clicking on the Verification of Digitally Signed Document and any angular transfer of 2016 1892 21400078; IV

Zilla Public School, Tannuk