



Government Of West Bengal  
Office Of The Divisional Fire Officer, Purba Medinipur  
West Bengal Fire & Emergency Services  
Dharinda, P.O.- Tamluk, Purba Medinipur, Pin:- 721636

Memo no.: WBFES/HOW/413/15

Date: 27-01-2021

From:  
Divisional Fire Officer, Purba Medinipur  
West Bengal Fire & Emergency Services

To: ZILLA PUBLIC SCHOOL  
TAMLUK, PURBA MEDINIPUR

Subject: Revised Fire Safety Recommendation for existing 2nd floor construction of G+II under group of Educational Building in the name & style of "ZILLA PUBLIC SCHOOL" at Village- Sankarara. P.O.-Tamluk P.S- Tamluk, District- Purba Mednipur- 721636.

This is in reference to your application no. 0125188211400003 dated 12-01-2021 regarding the Revised Fire Safety Recommendation for existing 2nd floor construction of G+II under group of Educational Building in the name & style of "ZILLA PUBLIC SCHOOL" at Village- Sankarara. P.O.-Tamluk P.S- Tamluk, District- Purba Mednipur- 721636.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Revised Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

**Recommendation:**

**CONSTRUCTION:**

1. The whole construction of the existing building shall be carried out as per approved plan drawings conforming the relevant building rules of local Panchayat Body.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. Provision of ventilation at the crown of the central core-duct of the building shall be provided.
4. Arrangement shall have to be made for sealing all the vertical and horizontal ducts by the materials of adequate fire resisting capacity.

**OPEN SPACE AND APPROACH:**

1. The open spaces surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire Appliances with turning facility.
2. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting 45M.T.
3. The width and height of the access gate into the premises shall not be less than 4.5 mts. and 5.0 mts. respecting the abutting road.
4. Drive way should be free from any type of obstruction. No parking will be allowed on the drive way.

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125188211400003.

Page : 1

প্রাচীর / Principal  
জিলা পাবলিক স্কুল, তামলুক  
Zilla Public School, Tamluk

Powered By emSigner For secure paperless solutions  
Please visit [www.emsigner.com](http://www.emsigner.com)