

GOVERNMENT OF WEST BENGAL
OFFICE OF THE CHIEF MEDICAL OFFICER OF HEALTH
DISTRICT HEALTH & FAMILY WELFARE SAMITI PURBA MEDINIPUR DISTRICT
Registration No. S/IL/10904 of 2002-03
Tamluk, Dist-Purba Medinipur, Pin-721636
E-mail : qapmdt@gmail.com Tele No. (03228)270-437


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 467

Dated: 14/8/2026

It is certified that an inspection team headed by Dr. Sumit Ganguly, CMOH & Secretary DH&FWS from PHED Inspected the Zilla Public School – Vill-Sankarara, P.O.- Tamluk, P.S.- Tamluk , Dist- Purba Medinipur, Paschim Medinipur, West Bengal- 721636 on 13-08-2026 and on the basis of Water Test Report (Attached) bearing no. ZPS/WP/2627 dated 11-08-2026 of PHED Lab certified that the Zilla Public School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ...13/8/2027...


CMOH & Secretary
DH&FWS, Purba Medinipur

Govt. of West Bengal
Public Health Engineering
GRIPS eChallan



192026270179597188

GRN Details

GRN:	192026270179597188	Payment Mode:	SBI Epay
GRN Date:	11/08/2026 12:33:19	Bank/Gateway:	SBIePay Payment Gateway
BRN :	5864542347137	BRN Date:	11/08/2026 12:34:41
Gateway Ref ID:	374873659426	Method:	State Bank of India UPI
GRIPS Payment ID:	110820262017959717	Payment Init. Date:	11/08/2026 12:33:19
Payment Status:	Successful	Payment Ref. No:	TEST [REF No]

Depositor Details

Depositor's Name:	ZILLA PUBLIC SCHOOL
Address:	SANKARARA, WARD NO 15 ,TAMLUK, PURBA MEDINIPUR
Mobile:	7003372278
EMail:	zillapublicschool@gmail.com
Contact No:	9679813167
Depositor Status:	Depositor
R.E.F. No:	TEST
Name:	ZILLA PUBLIC SCHOOL
Address:	SANKARARA , WARD NO 15 ,TAMLUK, PURBAMEDINIPUR
Period From (dd/mm/yyyy):	11/08/2026
Period To (dd/mm/yyyy):	11/10/2027
Remarks:	WATER SAMPLE TEST

Payment Details

Sl. No.	Payment Ref No	Head of A/C Description	Head of A/C	Amount ()
1	TEST	Collection of fees earned through testing of Private Water Samples in PHE Department Laboratories	0215-01-104-002-27	1400
Total				1400

IN WORDS: ONE THOUSAND FOUR HUNDRED ONLY.



Government of West Bengal

Office of the Assistant Engineer, Tamluk Sub-Division, P.H.E. Dte.
P.H.E. Complex (Ground Floor), Parbatipur, Tamluk, Purba Medinipur, PIN-721636
Mail ID:-ae tmlk sadar@wbphed.gov.in, Phone No.:-03228-266-189

DATE: 18.08.2026

Serial no: 261


TEST REPORT
MONTH OF AUGUST, 2026

Ref. No. : ZPS/WP/2627	Date: 06.08.2026	Source : Water Purifier			
GRN NO : 19-202627-017959718-8	Date: 11.08.2026				
Sender Name: Principal, Zilla Public School		Dist: Purba Medinipur			
Name of Place: Sankarara, Tamluk					
Habitation:- Zilla Public School		12.08.2026			
Date of Collection:		Self			
Sample Collection By:					
PARAMETERS	UNITS	STANDARD QUALITY As Per IS:10500		RESULT OF SAMPLE	
		Acceptable Limit	Permissible Limit	Sample- I	Remarks
pH	-	6.5-8.5	No Relaxation	7.33	Safe
TEMPERATURE	°C	-	-	25.6	Safe
TURBIDITY	NTU	1	5	0.39	Safe
TDS	mg/L	500	2000	213	Safe
CONDUCTIVITY	(μS/Cm)	-	-	361	Safe
CHEMICAL					
IRON	mg/L	1.0	No Relaxation	0.13	Safe
CHLORIDE	mg/L	250	1000	34.03	Safe
HARDNESS	mg/L	200	600	100	Safe
ALKALINITY	mg/L	200-	600	164	Safe
MANGANESE	mg/L	0.1	0.3	0.05	Safe
BACTERIOLOGICAL					
TOTAL COLIFORM	CFU	Shall not be detectable in 100ml		0	Safe
FAECAL COLIFORM	CFU	Shall not be detectable in 100ml		Absent	Safe

➤ Sample tested as received


Laboratory Analyst
Tamluk Sub-Division PHE Dte


Junior Engineer
Tamluk Sub-Division PHE Dte


Assistant Engineer
Tamluk Sub-Division PHE Dte